



EC CERTIFICATE

EC – CERTIFICATE OF CONFORMITY 0843 – CPD – 0120

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Firebreak 22 Penetration Seal and Linear Joint Seal Classified for use in flexible walls, solid walls and solid floors

A sealant used to seal around cables and metallic pipes to form a penetration seal to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services. The sealant may also be used to seal linear gaps and joints in and between wall and floor constructions to reinstate the fire resistance performance of wall and floor constructions, where they abut or include gaps. Firebreak 22 is supplied in liquid form contained within 310 ml cartridges, 600ml foils or in 5, 10, 15 or 19 litre tubs. The sealant is gunned or trowelled into the aperture in or between the separating element/elements and where appropriate around the service or services, to a specified depth utilising various backing materials.

placed on the market by

**Neutron Fire Technologies Limited
Shire Hall
Quay Street
Lostwithiel
Cornwall
PL22 0BS**

and produced in the factory

A/001

is submitted by the manufacturer to a Factory Production Control and that the approved body UL International (UK) Ltd., Notified Body 0843 has performed the Initial Type-Testing for the relevant characteristics of the product, the Initial Inspection of the factory and of the Factory Production Control and performs the continuous surveillance, assessment and approval of the Factory Production Control.

This certificate attests that all provisions concerning the attestation of conformity and the performance described in:

ETA 13/0070, ETA 13/0071, ETAG 026-2 & ETAG 026-3

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 04 February 2013 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

First issue date: 04 February 2013

Signature

Karl Harland
for UL International (UK) Ltd.



EC CERTIFICATE

Annex: Detailed information sheet

Certificate Number: 0843-CPD-0120

Product/Device description:

Firebreak 22

Applicant designation:

Neutron Fire Technologies Limited

Shire Hall
Quay Street
Lostwithie
Cornwall
PL22 0BS

Product Information

Firebreak 22

The referenced product complies with:

A – All the relevant requirements as per ETA 13/0070, ETA 13/0071, ETAG 026-2 & ETAG 026-3

Issue date: 04 February 2013

Signature

Karl Harland
for UL International (UK) Ltd.