



# EC CERTIFICATE

## EC – CERTIFICATE OF CONFORMITY 0843 – CPD – 0133

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

### **Sealfire W1000 Compound Penetration Seal Classified for use in solid walls and solid floors**

A mortar used to seal around cables and metallic pipes to form a penetration seal to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services. Sealfire W1000 Compound is supplied as a dry material, and is mixed with water to the required ratio prior to installation.

placed on the market by

**Neutron Fire Technologies Limited  
Shire Hall  
Quay Street  
Lostwithiel  
Cornwall  
PL22 0BS**

and produced in the factory

**A/002**

is submitted by the manufacturer to a Factory Production Control and that the approved body UL International (UK) Ltd., Notified Body 0843 has performed the Initial Type-Testing for the relevant characteristics of the product, the Initial Inspection of the factory and of the Factory Production Control and performs the continuous surveillance, assessment and approval of the Factory Production Control.

This certificate attests that all provisions concerning the attestation of conformity and the performance described in:

**ETA 13/0387, ETAG 026-2**

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 24<sup>th</sup> May 2013 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

First issue date: 24<sup>th</sup> May 2013

Signature

Karl Harland



# EC CERTIFICATE

## Annex: Detailed information sheet

Certificate Number: 0843-CPD-0133

### Product/Device description:

Sealfire W1000 Compound

### Applicant designation:

**Neutron Fire Technologies Limited**

Shire Hall  
Quay Street  
Lostwithiel  
Cornwall  
PL22 0BS

### Product Information

Sealfire W1000 Compound

The referenced product complies with:

A – All the relevant requirements as per ETA 13/0387, ETAG 026-2

### ETA Valid to date:

ETA 13/0387 – 8<sup>th</sup> April 2018

Issue date: 24th May 2013

Signature

Karl Harland  
for UL International (UK) Ltd.